

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0078:201 Page 1 of 1

CATEGORY: Annunciators

LISTEE: ADEMCO, 165 Eileen Way Syosset, NY 11791
Contact: Dave Kalmus (516) 921-6704.

DESIGN: Models FSA-8, FSA-24 annunciator and Model FSASM keyswitch module. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed annunciator and keyswitch module for use with separately listed and compatible fire alarm control units. For indoor use only.

NOTE: The use of the "SILENCE/RESET" feature is subjected to the approval of the authority having jurisdiction.

04-02-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager